




Generic Environmental Impact Statement on Decommissioning of Nuclear Facilities



Supplement 1



**Regarding the Decommissioning of
Nuclear Power Reactors**



Main Report, Appendices A through M

Final Report



**U.S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Washington, DC 20555-0001**



AVAILABILITY OF REFERENCE MATERIALS IN NRC PUBLICATIONS

NRC Reference Material

As of November 1999, you may electronically access NUREG-series publications and other NRC records at NRC's Public Electronic Reading Room at <http://www.nrc.gov/reading-rm.html>.

Publicly released records include, to name a few, NUREG-series publications; *Federal Register* notices; applicant, licensee, and vendor documents and correspondence; NRC correspondence and internal memoranda; bulletins and information notices; inspection and investigative reports; licensee event reports; and Commission papers and their attachments.

NRC publications in the NUREG series, NRC regulations, and *Title 10, Energy*, in the Code of *Federal Regulations* may also be purchased from one of these two sources.

1. The Superintendent of Documents
U.S. Government Printing Office
Mail Stop SSOP
Washington, DC 20402-0001
Internet: bookstore.gpo.gov
Telephone: 202-512-1800
Fax: 202-512-2250
2. The National Technical Information Service
Springfield, VA 22161-0002
www.ntis.gov
1-800-553-6847 or, locally, 703-605-6000

A single copy of each NRC draft report for comment is available free, to the extent of supply, upon written request as follows:

Address: Office of the Chief Information Officer,
Reproduction and Distribution
Services Section
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

E-mail: DISTRIBUTION@nrc.gov
Facsimile: 301-415-2289

Some publications in the NUREG series that are posted at NRC's Web site address <http://www.nrc.gov/reading-rm/doc-collections/nuregs> are updated periodically and may differ from the last printed version. Although references to material found on a Web site bear the date the material was accessed, the material available on the date cited may subsequently be removed from the site.

Non-NRC Reference Material

Documents available from public and special technical libraries include all open literature items, such as books, journal articles, and transactions, *Federal Register* notices, Federal and State legislation, and congressional reports. Such documents as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings may be purchased from their sponsoring organization.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at—

The NRC Technical Library
Two White Flint North
11545 Rockville Pike
Rockville, MD 20852-2738

These standards are available in the library for reference use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from—

American National Standards Institute
11 West 42nd Street
New York, NY 10036-8002
www.ansi.org
212-642-4900

Legally binding regulatory requirements are stated only in laws; NRC regulations; licenses, including technical specifications; or orders, not in NUREG-series publications. The views expressed in contractor-prepared publications in this series are not necessarily those of the NRC.

The NUREG series comprises (1) technical and administrative reports and books prepared by the staff (NUREG-XXXX) or agency contractors (NUREG/CR-XXXX), (2) proceedings of conferences (NUREG/CP-XXXX), (3) reports resulting from international agreements (NUREG/IA-XXXX), (4) brochures (NUREG/BR-XXXX), and (5) compilations of legal decisions and orders of the Commission and Atomic and Safety Licensing Boards and of Directors' decisions under Section 2.206 of NRC's regulations (NUREG-0750).

**Generic Environmental
Impact Statement on
Decommissioning of
Nuclear Facilities**

Supplement 1

**Regarding the Decommissioning of
Nuclear Power Reactors**

Main Report, Appendices A through M

Final Report

Manuscript Completed: October 2002
Date Published: November 2002

**Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001**



Abstract

This document is a supplement to the U.S. Nuclear Regulatory Commission (NRC) document *Final Generic Environmental Impact Statement on Decommissioning of Nuclear Facilities* issued in 1988 (NUREG-0586, referred to here as the 1988 Generic Environmental Impact Statement [GEIS]). This Supplement was prepared because of technological advances in decommissioning operations, experience gained by licensees, and changes made to NRC regulations since the 1988 GEIS.

This Supplement updates the information provided in the 1988 GEIS. It is intended to be used to evaluate environmental impacts during the decommissioning of nuclear power reactors as residual radioactivity at the site is reduced to levels that allow for termination of the NRC license. This Supplement addresses only the decommissioning of nuclear power reactors licensed by the NRC. It updates the sections of the 1988 GEIS relating to pressurized water reactors, boiling water reactors, and multiple reactor stations. It goes beyond the 1988 GEIS to explicitly consider high-temperature gas-cooled reactors and fast breeder reactors. This document can be considered a stand-alone document for power reactor facilities such that readers should not need to refer back to the 1988 GEIS. The environmental impacts described in this Supplement supercede those described for power reactor facilities in the 1988 GEIS.

The scope of this Supplement is based on the decommissioning activities performed to remove radioactive materials from structures, systems, and components from the time that the licensee certifies that it has permanently ceased power operations until the license is terminated. The scope of the document was determined through public scoping meetings and meetings with other Federal agencies and the nuclear industry. An evaluation process was then developed to determine environmental impacts from nuclear power reactor facilities that are being decommissioned. The evaluation process involved determining the specific activities that occur during reactor decommissioning and obtaining data from site visits and from licensees at reactor facilities currently being decommissioned. The data obtained from the sites were analyzed and then evaluated against a list of variables that defined the parameters for facilities that are currently operating but which will one day be decommissioned. This evaluation resulted in a range of impacts for each environmental issue that may be used for comparison by licensees that are or will be decommissioning their facilities.

Executive Summary

This document is a supplement to the U.S. Nuclear Regulatory Commission (NRC) document *Final Generic Environmental Impact Statement on Decommissioning of Nuclear Facilities*, issued in 1988 (NUREG-0586, referred to hereafter as the 1988 Generic Environmental Impact Statement [GEIS]).^(a) As a supplement, this document considers the technological advances in decommissioning, the experience gained by licensees, and changes made to NRC regulations since the 1988 GEIS. The information from the 1988 GEIS that is still current and applicable to permanently shut down and currently operating commercial nuclear power reactors is included here. This Supplement is intended to be used to evaluate environmental impacts during the decommissioning of nuclear power reactors as residual radioactivity at the site is reduced to levels that allow for termination of the NRC license.

The NRC elected to supplement the GEIS:

- (1) to further the purposes of the National Environmental Policy Act (NEPA)
- (2) to update the information in the GEIS
- (3) to provide additional information to the public on decommissioning activities
- (2) to establish an envelope of environmental impacts that could be associated with decommissioning activities.

Unlike the 1988 GEIS, which took a broad look at decommissioning of a variety of sites and activities, this Supplement addresses only nuclear power reactors licensed by the NRC. It updates the sections of the 1988 GEIS relating to pressurized water reactors, boiling water reactors, and multiple reactor stations. It goes beyond the 1988 GEIS and considers the existing permanently shut down high-temperature gas-cooled reactor and fast breeder reactor. It does not include research and test reactors or the power reactor facilities that have been involved in a significant accident resulting in large-scale contamination of structures, systems, and components (SSCs). It also does not include other types of fuel-cycle facilities, such as fuel-reprocessing plants or small mixed oxide fuel-fabrication plants.

The intent of this Supplement is to consider in a comprehensive manner all aspects related to the radiological decommissioning of nuclear reactor facilities by incorporating updated information, regulations, and analyses. Since the 1988 GEIS was written, the NRC and the industry have gained substantially more nuclear power facility decommissioning experience. Based on the number of reactors shut down and the date that they permanently ceased

(a) The GEIS is considered "generic" in that it evaluates environmental impacts from decommissioning activities common to a number of nuclear power facilities.

Executive Summary

operations, over 200 facility-years' worth of decommissioning experience have accumulated since the NRC published the 1988 GEIS. Currently, there are 19 commercial power reactor facilities in the decommissioning process. This includes nine that permanently ceased operations after the NRC published the 1988 GEIS. Since the 1988 GEIS, there are three facilities that have completed decommissioning and terminated their licenses. There are also new technologies and approaches applicable to decommissioning that the 1988 GEIS does not address. The regulations for decommissioning reactors have also undergone significant changes since the 1988 GEIS.

Scope of the Supplement

The content of this Supplement was initially defined by the scope of the 1988 GEIS and was modified based on current decommissioning regulations, input received during four public scoping meetings, letters and comments received during the scoping period, and meetings between the NRC and the U.S. Environmental Protection Agency (EPA) and the Council on Environmental Quality (CEQ). The public comments received during the scoping process that were considered to be within the scope of the environmental review are provided in Volume 2 Appendix N. The NRC staff published for comment Supplement 1 to the GEIS in October 2001. Public meetings in San Francisco, California, Boston Massachusetts, Chicago, Illinois and Atlanta, Georgia were held in December, 2001 to describe the preliminary results of the NRC environmental review, to answer questions, and to provide members of the public with information to assist them in formatting comments on the draft Supplement. All comments received on the draft Supplement were considered by the staff in developing the final document and are presented in Appendices O and P.

The scope of this Supplement is based on the decommissioning activities performed to remove radioactive materials from SSCs from the time that the licensee certifies that it has permanently ceased power operations until the license is terminated. As a result, the activities performed before permanent cessation of operations (except for decommissioning planning) or impacts that are related to the decision to permanently cease operations (for example, the impact from the loss of generation capacity) are outside the scope of this document.

The Commission defines decommissioning as "to remove a facility or site safely from service and reduce residual radioactivity to a level that permits (1) Release of the property for unrestricted use and termination of the license; or (2) Release of the property under restricted conditions and termination of the license." The staff has included activities that are directly related to the removal of radioactive material from the facility or that must be performed in order to facilitate the removal of contaminated SSCs, as well as the activities and impacts related to the removal of uncontaminated SSCs (such as the intake structure or cooling towers) that were required for the operation of the reactor.

The decommissioning process continues until the licensee requests termination of the license and demonstrates that radioactive material has been removed to the levels that permit

termination of the NRC license. At that point, the NRC no longer has jurisdiction over the site and the owner of the site is no longer subject to NRC regulations. As a result, activities performed after license termination and the resulting impacts are outside the scope of this Supplement. These activities may include any non-NRC required monitoring, site restoration (grading, planting of vegetation, etc.), continued dismantlement (removal of uncontaminated structures or those that have been radiologically decontaminated), or continued use of the site for activities such as power production using natural gas, oil, or coal.

Any potential radiological impacts following license termination that are related to activities performed during the decommissioning period are not considered in this Supplement. Those impacts are covered by the *Generic Environmental Impact Statement in Support of Rulemaking on Radiological Criteria for License Termination of NRC-Licensed Nuclear Facilities* (NUREG-1496). Nonradiological impacts following license termination that are related to activities performed during the decommissioning period are considered in this Supplement.

Levels of Significance and Applicability of Environmental Impacts

This Supplement provides a measure of (a) the significance and severity of potential environmental impacts and (b) the applicability of these impacts to a variety of plants both permanently shut down and operating. The significance of the environmental impacts is described as either SMALL, MODERATE or LARGE. The applicability of these impacts to a variety of plants is categorized as either generic or site-specific.

Levels of Significance: For decommissioning, the staff is using a standard of significance derived from the CEQ terminology for "significantly" (40 CFR 1508.27, which considers "context" and "intensity"). The NRC has defined three significance levels: SMALL, MODERATE, and LARGE.

SMALL - Environmental impacts are not detectable or are so minor that they will neither destabilize nor noticeably alter any important attribute of the resource. For the purposes of assessing radiological impacts in this Supplement, the NRC has concluded that those impacts that do not exceed permissible levels in the Commission's regulations are considered small.

MODERATE - Environmental impacts are sufficient to alter noticeably but not to destabilize important attributes of the resource.

LARGE - Environmental impacts are clearly noticeable and are sufficient to destabilize important attributes of the resource.

The discussion of each environmental issue in this Supplement includes an explanation of how the significance level was determined. In determining the significance level, the NRC staff assumed that ongoing mitigation measures would continue (including those mitigation

Executive Summary

measures implemented during plant construction and/or operation) during decommissioning, as appropriate. Benefits of additional mitigation measures during or after decommissioning are not considered in determining significance levels.

Applicability: In addition to determining the significance of environmental impacts, this Supplement includes a determination of whether the analysis of the environmental issues could be applied to all plants, and whether additional mitigation measures would be warranted. An environmental issue may be assigned to one of two categories:

- Generic - For each environmental issue, the analysis reported in this Supplement shows the following:
 - (1) Environmental impacts associated with the issue have been determined to apply either to all plants, or for some issues to plants of a specific size, specific location or having a specific type of cooling system or site characteristics, and
 - (2) A single significance level (i.e., SMALL, MODERATE, or LARGE) has been assigned to the impacts, and
 - (3) Mitigation of adverse impacts associated with the issue has been considered in the analysis, and it has been determined that additional plant-specific mitigation measures are likely not to be sufficiently beneficial to warrant implementation.
- Site-specific - For each environmental issue that was determined to be site-specific, the analysis reported in this Supplement has shown that one or more of the generic criteria was not met. Therefore, additional plant-specific review is required. An example of a site-specific issue is threatened and endangered species.

Use and Development of this Supplement

This Supplement can be used by the public to understand the decommissioning process, the activities performed during decommissioning, and the potential environmental impacts resulting from these activities. It identifies activities that can be bounded by a generic evaluation. Licensees can rely on the information in this Supplement as a basis for meeting the requirements in 10 CFR 50.82(a)(6)(ii). This requirement states that the licensee must not perform any decommissioning activity that causes any significant environmental impact not previously reviewed. The NRC staff will also rely on this Supplement as a basis for determining if anticipated decommissioning impacts require an additional review.

The staff first created an initial list of environmental issues and activities that this Supplement should address. The initial list of environmental issues was developed from issues (such as air

quality, aquatic ecology, and radiological impacts) identified in the 1988 GEIS and in the list specified in 10 CFR Part 51, Subpart A, Appendix B, for license renewal. This list was used because it represents the potential impacts associated with nuclear power facilities. The initial list of decommissioning activities was modified based on experience, public participation in the scoping process, site visits to six facilities currently being decommissioned, and meetings with EPA and CEQ. After compiling the issue and activity lists, the staff assessed which activities might have environmental impacts for each of the issues. The next step was to identify the variables that might affect the decommissioning impact for a specific issue and activity. For example, the proximity of the plant to a barge slip or railroad might affect the licensee's decision to remove the steam generator or other large components intact and ship them to a waste site. If the barge slip needs additional dredging, or an additional railroad line needs to be installed, then the environmental impacts may change.

The analyses in this Supplement include data from both operating and decommissioning facilities in order to appropriately span the range of impacts that could be expected. Data from decommissioning facilities was used to determine whether the potential impacts from decommissioning activities for the various issues are generic or site-specific. Data from operating facilities were used to ensure that this Supplement will be valid for all commercial nuclear power reactors.

Alternatives

The alternative to the action of decommissioning is not to decommission the facility. The option to restart the reactor is not considered to be an alternative to decommissioning because the decision to permanently cease operation prevents the licensee from operating the reactor without a significant safety and environmental review by the NRC staff.

The alternative to decommissioning at the end of the licensing period is a "no action" alternative, implying that a licensee would simply abandon or leave a facility after ceasing operations. NRC regulations do not allow the option of not decommissioning. Once the facility permanently ceases operation, if the licensee does not conduct decommissioning activities to an extent that meets the license termination criteria in 10 CFR Part 20, Subpart E, then the license will not be terminated (although the licensee will not be authorized to operate the reactor). The licensee will be required to comply with the necessary requirements for the operating license. As a result, the environmental impacts for maintaining the nuclear reactor facility will be considered to be in the bounds of the appropriate, previously issued Environmental Impact Statements. Under NRC regulations, the original operating license for a nuclear power plant is issued for up to 40 years. The license may be renewed for periods of up to 20 years if NRC requirements are met. However, at the end of the licensing period (whether it has been extended or not), the regulations require that the facility be decommissioned.

Executive Summary

Conclusions

Table ES-1 presents each evaluated environmental issue and identifies whether the issue is considered generic or site-specific. If the issue is considered generic, then it is assigned a significance level of either SMALL, MODERATE or LARGE. Of the environmental issues assessed, most of the impacts are generic and SMALL for all plants regardless of the activities and identified variables (see Appendix E for a list of the variables). The two issues determined to be site-specific are threatened and endangered species and environmental justice. Four issues are considered to be conditionally site-specific.

- land use involving offsite areas to support decommissioning activities
- aquatic ecology for activities beyond the operational area
- terrestrial ecology for activities beyond the operational area
- cultural and historic resources for activities beyond the operational area with no current cultural and historic resource survey.

The operational area is defined as the portion of the plant site where most or all of the site activities occur, such as reactor operation, materials and equipment storage, parking, substation operation, facility service, and maintenance. This includes areas within the protected area fences, the intake, discharge, cooling, and associated structures as well as surrounding paved, graveled, maintained landscape, or other maintained areas.

Licensees undergoing or planning decommissioning of a commercial nuclear power reactor can use this Supplement in support of their evaluation of the environmental consequences from decommissioning. The impacts identified in this Supplement are designed to span the range of impacts from all plants that are currently permanently shut down as well as the plants that are currently operating, including the plants that have or may renew their licenses beyond the original 40-year license; a renewed license can be issued for a period not to exceed 20 years beyond the expiration of the operating license. When planning a specific decommissioning activity, licensees that fall within the bounds of the impacts, as described in Chapter 4, may proceed with the activity with no further analysis. However, if the planned activity could result in environmental impacts greater than those predicted by this supplement, then the activity cannot be performed until the licensee performs a site-specific analysis of the activity. Depending on the results of the site-specific evaluation, the staff may determine that it is appropriate to consult with another agency (such as the U.S. Fish and Wildlife Service or a State Historic Preservation Office). If the activity would result in an impact that is outside the bounds of the GEIS or other environmental assessments, the licensee would be required to submit a license-amendment request.

Table ES-1. Summary of the Environmental Impacts from Decommissioning Nuclear Power Facilities

Issue	Generic	Impact
Onsite/Offsite Land Use		
- Onsite land use activities	Yes	SMALL
- Offsite land use activities	No	Site-specific
Water Use	Yes	SMALL
Water Quality		
- Surface water	Yes	SMALL
- Groundwater	Yes	SMALL
Air Quality	Yes	SMALL
Aquatic Ecology		
- Activities within the operational area	Yes	SMALL
- Activities beyond the operational area	No	Site-specific
Terrestrial Ecology		
- Activities within the operational area	Yes	SMALL
- Activities beyond the operational area	No	Site-specific
Threatened and Endangered Species	No	Site-specific
Radiological		
- Activities resulting in occupational dose to workers	Yes	SMALL
- Activities resulting in dose to the public	Yes	SMALL
Radiological Accidents	Yes	SMALL
Occupational Issues	Yes	SMALL
Cost	NA ^(a)	NA
Socioeconomic	Yes	SMALL
Environmental Justice	No	Site-specific
Cultural and Historic Resource Impacts		
- Activities within the operational areas	Yes	SMALL
- Activities beyond the operational areas	No	Site-specific
Aesthetics	Yes	SMALL
Noise	Yes	SMALL
Transportation	Yes	SMALL
Irretrievable Resources	Yes	SMALL

(a) A decommissioning cost assessment is not a specific National Environmental Policy Act (NEPA) requirement. However, an accurate decommissioning cost estimate is necessary for a safe and timely plant decommissioning. Therefore, this Supplement includes a decommissioning cost evaluation, but the cost is not evaluated using the environmental significance levels nor identified as a generic or site-specific issue.